On the utilisation of the pseudocapacitive capabilities of Li-ion cells for the provision of frequency response services

Rogall, M., Amietszajew, T., Bhagat, R., Brucoli, M. & Greenwood, D.

Published PDF deposited in Coventry University's Repository

Original citation:

Rogall, M, Amietszajew, T, Bhagat, R, Brucoli, M & Greenwood, D 2019, 'On the utilisation of the pseudo-capacitive capabilities of Li-ion cells for the provision of frequency response services' Journal of Energy Storage, vol. 22, pp. 311-317. https://dx.doi.org/10.1016/j.est.2019.02.028

DOI 10.1016/j.est.2019.02.028 ESSN 2352-152X

Publisher: Elsevier

© 2019 The Authors. Published by Elsevier Ltd. This is an open access article under the CC BY license (http://creativecommons.org/licenses/BY/4.0/).

Copyright © and Moral Rights are retained by the author(s) and/ or other copyright owners. A copy can be downloaded for personal non-commercial research or study, without prior permission or charge. This item cannot be reproduced or quoted extensively from without first obtaining permission in writing from the copyright holder(s). The content must not be changed in any way or sold commercially in any format or medium without the formal permission of the copyright holders.



Contents lists available at ScienceDirect

Journal of Energy Storage



journal homepage: www.elsevier.com/locate/est

On the utilisation of the pseudo-capacitive capabilities of Li-ion cells for the provision of frequency response services



Martin Rogall^{a,*}, Tazdin Amietszajew^a, Rohit Bhagat^a, Maria Brucoli^b, David Greenwood^a

^a WMG, The University of Warwick, Coventry, CV4 7AL, UK

^b EDF Energy, Interchange, 81- 85 Station Rd, Croydon, CRO 2AJ, UK

ARTICLE INFO	A B S T R A C T			
Keywords:	This work investigates the capacitive capabilities of Li-ion pouch and cylindrical cells in respect to the provision of			
Li-Ion EIS Capacitance Frequency response	Frequency Response services and a potential for reduction in battery ageing effects. This is achieved using Electrochemical Impedance Spectroscopy (EIS) and a novel method of identifying and defining the threshold frequency between pseudo-capacitive and diffusion processes of the cell. It is found that this threshold frequency is independent of current intensity up to 1 C, showing that even at high power, pseudo-capacitance has significant impact. However, a severe dependency upon relative cell surface area and State of Charge (SoC) is identified. Symmetrical charge-discharge pulses of up to 10 s utilise primarily cell capacitance. Literature indicates, that this level of utilisation reduces the electrochemical ageing impact significantly. This article displays a method to			
	level of utilisation reduces the electrochemical ageing impact significantly. This article displays a method identify and isolate these processes for any given cell and to allow enhancement of conventional ageing modellir			

1. Introduction

Mandatory and Firm Frequency Response (MFR and FFR) are services demanded and requested by National Grid, which balance demand and generation on a permanent basis in the Great British power grid [1]. In 2016, National Grid introduced additionally the Enhanced Frequency Response (EFR) service, which aims to replace the inertia effects from conventional energy sources by use of even shorter response time [2]. All of these services are provided through counterbalancing over-demand and -generation with rapid output power changes – a service for which batteries on large scale, especially for EFR, have emerged as the most suitable technology [3,4].

Several papers [5–10] discuss the potential of batteries and specifically Li-Ion batteries to provide inertia to the grid in the form of frequency response. Several authors [8,6–10] compared retrospectively the ageing to the medium SoC and cycle depth of the utilisation. In one instance [10], the ageing impact of frequency response on the battery has primarily been ascribed to calendric degradation. All these investigations account for the degradation cumulatively for a prolonged time period, however they do not consider important differences between frequency response provision and standard cycling in short time scales. These phenomena, such as fast pulsing and high currents, can have significant impact on the ageing of Li-Ion cells, which asks for deeper analysis as proposed in this work.

The authors of [9,11–13] describe based on EIS results that battery cells, specifically Li-ion cells, exhibit capacitive properties when exposed to a high frequency alternating current. These properties are due to polarisation and pseudo-capacitive processes within the cell, which behave like purely electrical non-ideal capacitors and thus don't represent an electrochemical charge/discharge process. At lower frequencies, the chemical diffusion processes are activated, and the battery functions more conventionally.

Cycling batteries has been proven to have higher impact on the ageing of Li-ion cells than pure storage periods [14–16]. Under the hypothesis that some actions during the provision of frequency response only utilise the capacitive effects within the cell due to high frequency AC operation, it is reasonable to assume that these actions have much lower impact on the electrochemical ageing of the cell than other applications with equivalent throughput.

During Micro-Cycling [17–19] batteries are subjected to small charge and discharge processes, resulting in a low cycle depth. The authors of [17] applied over 200,000 micro-cycles (equal to 3000 full equivalent cycles) to Nickel-Manganese-Cobalt/Carbon (NMC/C) battery cells. Over this time period, the authors did not detect any capacity fade or resistance increase. The authors do not link this effect to the capacitive properties of the cell. Therefore, a thorough investigation into Li-Ion pseudo-capacitance would highly benefit ageing analysis.

There are several methods to determine the threshold between

* Corresponding author.

E-mail address: m.rogall@warwick.ac.uk (M. Rogall).

https://doi.org/10.1016/j.est.2019.02.028

Received 23 November 2018; Received in revised form 23 February 2019; Accepted 25 February 2019 Available online 01 March 2019 2352-152V (@ 2019 The Authors: Published by Elsevier Ltd. This is an open access article under the CC B

2352-152X/ © 2019 The Authors. Published by Elsevier Ltd. This is an open access article under the CC BY license (http://creativecommons.org/licenses/BY/4.0/).

capacitance and diffusion within the cell. For instance, utilising the Archimedes principle and submerging the cell into a liquid would enable measuring the electrode expansion and consequently the diffusion during cycling. This setup would, however, require highly sensitive measurement of the surface level and be biased by inhomogeneous thermal expansion of the liquid itself.

Another method is the use of a reference electrode to measure directly the potential of the electrodes during operation. However, since capacitive effects are present in both electrodes, this setup would not separate the processes correctly [20,21].

EIS provides a reliable and consistent way to analyse the electrical properties of battery cells [12,22–25]. Identifying the threshold between capacitive and chemical utilisation of the battery through EIS shows two major difficulties. Firstly, high-power utilisation of batteries generally shows non-linearities connected to the Butler-Volmer equation [12,24]. These non-linearities cause harmonics which are primarily prevalent at high currents and low frequencies, and can be identified through methods such as Nonlinear EIS or Nonlinear Frequency Response Analysis [26–28].

Secondly, distinguishing between the individual components of the Equivalent Circuit Model (ECM) commonly requires fitting it to the data, which further requires additional software tools. These may, especially under influence of non-linearities, not be capable of generating a sufficiently accurate result. Although this process can be supported through analysis of the distribution of relaxation times, this requires complex evaluation (manually or through further software) and only provides limited benefits to comparing the impact of the processes during utilisation [25,29–32].

This paper investigates the capacitive capabilities of NMC-LMO (Lithium-Manganese-Oxide), LFP (Lithium-Iron-Phosphate) and NMC cells. It aims to define a simpler and accurate method of identifying the threshold between capacitive and diffusion processes within a cell, to determine general characteristics and dependencies of this threshold and to connect these to the conditions of frequency response and the results found in [17].

2. Experimental design

The experimental design matrix is given in

Table 1. Four different cell types of different size, shape and chemistry from different manufacturers have been investigated in this experiment. Before, the test cell type A has been subjected to approximately 100 full equivalent cycles (CPCV between 2.8 V and 4.15 V) through emulation of support of a household-photovoltaic system. In this time period, the cell has not displayed significant ageing effects (< 2% capacity loss). Cell type B originates from a module disassembly and has been full cycled 7 times (CCCV at C/2 between 2.8 V and 4.15 V) prior to the test. Cell types C and D were provided as new cells.

The state of charge of type A and B has been adjusted before the EIS tests through C/2 charge current from 0% SoC using Coulomb counting. C and D were provided at 50% SoC.

The maximum currents have been chosen based on equipment limitations and the expected current during EFR. The maximum relative

Table 1

Experimental	Design	Matrix
--------------	--------	--------

ID	А	В	С	D
COUNT CHEMISTRY NEW FORM CAPACITY SOC RMS-CURRENT	3 NMC-LMO/C No Pouch 15 Ah 25 %, 50 %, 75 % C/20, C/10, C/5, C/2, 1C	4 NMC-LMO/C Yes Pouch 33 Ah 50 % C/16, C/3, 2/5C	1 LFP/C Yes Pouch 19.5 Ah 50 % C/10, C/2, 2/3C	1 NMC/C Yes Cylindrical 3.1 Ah 50 % C/10, C/2, 1C
TEMPERATURE	22 °C	22 °C	22 °C	22 °C

current that battery storage is allowed to provide is 2C [2], and typical frequency behaviour indicates that events with a required power output beyond 50% of the maximum output is extremely rare [33].

Galvanostatic EIS has been performed separately and consecutively (starting with the lowest current to reduce the impact on the SoC) for each of the RMS currents. The starting OCV for each state of charge varied by < 15 mV. The frequency band covered 5 kHz to 20 mHz. A Solartron ModuLab XM ECS potentiostat coupled with a 20 A booster has been used to perform the EIS [34].

3. Nyquist-plot analysis

Initially, EIS has been performed at varying currents to investigate the impact of the Butler-Volmer nonlinearity on the cells. The results are displayed in Fig. 1. High frequency positive reactances have been neglected in this display, as they are heavily influenced by cable inductivity. Furthermore, a few low frequency results of type B have been cut as they indicated behaviour of a closed Warburg element.

Fig. 1 shows, that increasing the current had no significant impact on the impedance of type A, B and C cells, indicating that the impedance non-linearity caused by high currents is minimal. However, cell type D was affected by increasing currents. Mainly the resistive part of the pseudo-capacitance and diffusion have been reduced by the increasing currents, confirming impacts by the Butler-Volmer kinetic.

The main differences between cell D and the others are size and architecture. Since the currents are adapted towards the cell capacity, it is more likely that the difference occurs due to the cylindrical shape, which constrains the cell contents and influences the cell properties.

Fig. 1 further displays the Nyquist plot of type A at changing SoC. At higher SoC resistance of conductor and pseudo-capacitance decreases, indicated by both the shift of the curves towards 0 and the contraction of the semi-circle. These changes appear to be exponential and match the behaviour described in [24]. However, the angle of the diffusion part of the curve is not significantly affected.

Based on the work of [9,11,13,23], the equivalent circuit model displayed in Fig. 2a was found to best represent the Nyquist plots in Fig. 1. R_0 represents the purely ohmic resistance, the SEI and CT subscripted elements display the pseudo-capacitive properties of the solid electrolyte interface and the charge transfer and CPE_{DIF} describes the diffusion processes through a constant phase element

4. Filtration of pseudo-capacitance and diffusion

The basis for the differentiation between the processes is the equivalent circuit model given in Fig. 2a. Since the individual elements are irrelevant for the distinction between pseudo-capacitance and diffusion, the ECM can be expressed as given in Fig. 2b, where Z_0 represents the conductor resistance, Z_{PC} the combined pseudo-capacitance and Z_{DIF} the diffusion. The conditions are as follows:

$$Z_0 = R_0 \tag{1}$$

$$Z_{PC} = \frac{R_{SEI}}{1 + B_{SEI}^*(j\omega)^{\psi_{SEI}}} + \frac{R_{CT}}{1 + B_{CT}^*(j\omega)^{\psi_{CT}}}$$
(2)

$$Z_{DIF} = \frac{1}{B_{DIF}^*(i\omega)^{\psi_{DIF}}}$$
(3)

$$Z = Z_0 + Z_{PC} + Z_{DIF} \tag{4}$$

R represents the ohmic characteristic of each element, *B* and ψ are the fitting parameters of the constant phase elements and ω describes the angular frequency.

Only two of these elements must be determined to fully capture the individual impedances. Z_0 can be determined through linear interpolation where the Z" is equal to zero. At low frequencies, the diffusion impedance is the only active element. Fitting $|Z_{CPE}|$ or Z'_{CPE} to the data requires knowledge of the resistive parameters of Z_{PC} . However, Z''_{CPE}



Fig. 1. Nyquist-Plots of the different cell types at different currents.

can be directly fitted towards the low frequency reactance Z" dataset from the EIS. An example fitting curve is displayed in Fig. 3.

The fitting data has been selected so that the covariance of B_{DIF} and ψ_{DIF} are minimal. The resulting fitting function describes almost perfectly the measurements for the types A, C and D. The reactance of type B was not perfectly fitted, where in some instances the fitted values were greater than the measured values. B_{DIF} and ψ_{DIF} and the RMSE for each fit have been determined for every measurement and are displayed in

Table 2. For type A and B the values have been averaged over all samples.

With this method, Z_0 and Z_{CPE} have been determined for every measured frequency and can be subtracted from each Z value. The resulting Nyquist plot of the pseudo-capacitance for different cases is given in Fig. 4. The resulting graph describes well the depressed semicircle of the pseudo-capacitive ZARC elements. Towards lower frequencies, inaccuracies become apparent. These are likely due to



Fig. 2. Chosen Equivalent Circuit Model (a) and complex simplification (b).



Fig. 3. EIS-measured reactance and fitted Z"_{DIF} function (Type A).

Table 2

Diffusion element parameters and RMSE.

Туре	SoC [%]	Current [A]	B_{DIF} [S]	ψ _{DIF} [°]	RMSE [%]
А	25	0.75	4543.80	40.85	3.85E-04
		1.5	4549.26	40.92	4.70E-04
		3	4677.51	41.29	3.81E-04
		7.5	4556.11	40.97	4.01E-04
		14.4	4694.82	41.04	3.63E-04
	50	0.75	5060.27	39.81	9.53E-03
		1.5	5188.33	40.23	8.90E-03
		3	5264.31	39.92	8.59E-03
		7.5	5075.32	39.26	8.40E-03
		14.4	4906.42	38.09	7.87E-03
	75	0.75	4154.34	39.04	3.08E-03
		1.5	4147.85	38.64	2.90E-03
		3	4215.73	39.24	2.36E-03
		7.5	4104.11	38.17	2.30E-03
		14.4	4107.67	37.93	3.58E-03
В	50	2.1	4953.25	23.68	2.83E-03
		10.5	4882.84	23.71	2.77E-03
		14	4895.66	23.57	2.77E-03
С	50	1.95	2459.65	32.12	4.69E-04
		9.75	2001.07	28.77	3.49E-03
		13	2208.62	29.18	3.49E-03
D	50	0.31	405.43	34.16	8.48E-04
		1.55	389.84	32.43	8.47E-05
		3.1	446.78	33.04	1.11E-03

measurement errors, characteristics that cannot be captured by simplified ECM and imperfect fitting.

Since these inaccuracies might negatively impact the following analysis and do not represent realistic behaviour, they need to be corrected. This is achieved by stating that Z'_{PC} does not decrease at lower frequencies and Z''_{PC} does not exceed zero. Through this, a more accurate approximation for Z_{PC} can be determined.

5. Bode graph analysis

To identify the absolute utilisation of the individual components, $|Z_0|$, $|Z_{PC}|$ and $|Z_{DIF}|$ have been plotted in the Bode Plot. It displays for each frequency, how the overpotential of the cell is split across the elements, and thus at which rate elements are utilised. A sample is displayed in Fig. 5. Added up, all components result in the impedance over the cell.

At very high frequencies (> 1000 Hz), the cell acts as a pure resistor with an ideal power source, meaning that every utilisation only generates ohmic losses and the cell is neither charged nor discharged. At medium frequencies (< 1000 Hz, > 1 Hz), the double-layer capacitance of the cell acts as an additional power source/surge during charge and discharge processes. At low frequencies (< 1 Hz), the diffusion

process is gradually activated, providing the electrochemical energy storage. However, in the initial stages of charge and discharge process, the cell is still utilising its capacitance.

Mathematically, neither capacitance nor diffusion are zero at any frequency. However, the mentioned thresholds can be assumed true for most real applications. Another threshold is defined here and is marked as a black vertical line in the graph. This transitional frequency, from here on called Capacitance-Diffusion Transitional Frequency (CDTF), marks the point where the impedance of the diffusion element is equal to the impedance of the capacitive element. Thus, capacitance and diffusion are equally utilised at CDTF. Above CDTF, the capacitance is the dominant element. Below CDTF, diffusion is dominant.

CDTF is not a hard border but provides an indication whether to consider capacitive effects or charge/discharge actions during utilisation analysis.

Within the same SoC range, the Bode plots for type A, B and C, respectively, are almost identical. However, as displayed in Fig. 6, the impedances of type D change expectedly. Even though $|Z_0|$ stays constant, both $|Z_{PC}|$ and $|Z_{DIF}|$ become smaller at higher currents. Since they both fall at approximately the same rate, the CDTF only varies slightly

6. CDTF analysis

The CDTF has been determined for all cells in all states. The results along with the errors across samples are displayed in Fig. 7. The CDTF across the first 3 types varies but appears to be almost always in the logarithmic area between 10 and 100 mHz. Type D is an exception with an average CDTF of about 3.5 mHz, which can be connected to the cylindrical design of the cell and the resulting maximised surface area and capacitance as found in capacitors. This prolongs the window during charge and discharge in which the capacitance is the primary effect.

The CDTF appears to be widely current-independent. Although there is a slight downwards trend in the CDTF towards higher currents in type B and D, these changes are minimal and within expected error range. As described in section 5, both $|Z_{PC}|$ and $|Z_{DIF}|$ of type D became smaller at higher currents, keeping the CDTF at approximately 3.5 mHz. Overall, current intensity does not seem to have any impact on the rate of utilisation of pseudo-capacitance and diffusion

However, the state of charge seems to have a significant impact. At higher SoC the CDTF rises as well, resulting in higher diffusion utilisation. At low SoC, the CDTF is minimal and thus the capacitive effects are maximised. In type A, the CDTF is twice as high at 75% than at 25%. The overall dependency appears to be exponential.

For almost all cases, the CDTF is located beyond the tested frequency spectrum (< 20 mHz). Since the terminal behaviour of the pseudo-capacitance and the diffusion has been identified, this does not impact the confidence in the results. However, this proves that the transition between the elements is far beyond the "valley" in the Nyquist plot.

7. Translation of frequency response utilisation into AC utilisation of battery

To analyse the relationship between the in [17] presented results, frequency response provision and CDTF, it is necessary to compare and translate the charge/discharge signals. AC utilisation requires a bidirectional (positive and negative power output) provision of frequency response. However, FFR and MFR describe a collection of unidirectional services [1,35]. Therefore, a bidirectional combination of these services is assumed. EFR is already defined as bidirectional service [36]. Fig. 8: Rectangular (left) and sawtooth (right) charge-discharge current profiles [17]Fig. 8 displays the rectangular pulse as it is assumed to be present for frequency response provision and a sawtooth pulse as it has been applied in [17].

Using the principles of Fourier transformation, these signals can be recreated by an endless combination of sinusoidal signals, with the lowest frequency being the inverse of the overall pulse time (a + b + c).





Fig. 5. Bode Plot for type A at 14.4 A and 50% SoC.



Fig. 6. Bode Plot for type D at 50% SoC.

Therefore, from the results in Section 6 the maximum pulse time for capacitive dominance can be determined by calculating the reciprocal of the CDTF. The maximum pulse time varies therefore between 10 s (cell type B) and 4.7 min (cell type D).

The documentation and guidance documents regarding FFR, MFR and EFR define the respective delay and maximum provision duration of each response [1,2,36–41]. However, for the consideration of AC signals, the change in grid frequency and the sampling rate for the provision are of higher relevance. The grid frequency is dependent upon the energy balance of the National Grid and is therefore changing constantly. The sampling rate is given for EFR as one reading every 100 ms [2], which results in a minimum symmetric pulse time of 200 ms. This is well below the maximum pulse time, meaning that provision of frequency response can result in pure utilisation of the cell capacitance.

Although National Grid is trialling new frequency response approaches and plans to revamp the balancing mechanism [42,43], the necessity of frequency response, the technical suitability of battery storage for this service, as well as the service's impact on the system are likely to remain similar.

The pulses applied in [17] had a duration of 40 s. Although it is not



Fig. 7. CDTF for changing currents and varying states of charge for all types.

guaranteed that the capacitance is the dominant process, it is very likely that the diffusion process is at least significantly reduced by the pseudo-capacitance. This makes pseudo-capacitance a valid possible explanation for the in [17] observed minimal cell ageing.

8. Conclusion

In this paper, a fast method has been presented to clearly differentiate between pseudo-capacitance and diffusion within a Li-ion cells by fitting the reactive impedance to CPE behaviour. This enables users to distinguish between electrical and electrochemical processes during charge and discharge of the cell. Through this method, the capacitancediffusion transitional frequency (CDTF) can be determined, which is a soft border for the respective dominant processes.

It has been shown, that this border is independent of the current intensity (up to 1C) and therefore not affected by non-linearities of internal resistance. However, it is apparent that there is an exponential relationship between this frequency and the SoC, wherein cells at lower SoC have higher capacitive capabilities. Furthermore, higher relative surface between anode and cathode seems to enhance them as well.

Analysis of this frequency and the requirements of frequency response services shows, that short-term symmetrical pulses are absorbed by the pseudo-capacitance of the cell. The results displayed in [17] indicate, that this utilisation significantly reduces the cell ageing in respect to throughput. A potential explanation would be that the reduction in diffusion reduces the mechanical stress on the cell caused by anode expansion, and therefore reduces the loss of active material [44].

However, even without diffusion processes, several other ageing processes such as the SEI formation might still be impacted by this utilisation. The increase in cell temperature as observed in [17] could even accelerate these processes. In future experiments it is therefore planned to perform further accelerated ageing studies comparing the impact of high frequency utilisation against low frequency utilisation of the cell.

If there is a benefit in operating a cell below CDTF, it would further



Fig. 8. Rectangular (left) and sawtooth (right) charge-discharge current profiles. [17].

be possible to investigate the ideal conditions for this utilisation under the perspectives of cell pressurisation, state of charge, cell age, temperature and super-positioning of sinusoidal with other signals.

Data Availability

The measurement data collected in this project is available from the corresponding author on request. Restrictions apply for data of commercial cells.

Acknowledgements

This project has been made possible through the EPSRC Centre for Doctoral Training in Sustainable Materials and Manufacturing (grant number: EP/L016389/1) and funding from EDF Energy. This research was done with support from the TRENDS project (reference number EP/ R020973/1).

References

- National Grid, Mandatory Frequency Response, (2018) Frequency Response Guide v1.1.pdf https://www.nationalgrid.com/sites/default/files/documents/Mandatory.
- [2] National Grid, Enhanced Frequency Response: Invitation to Tender for Pre-qualified Parties, (2016) http://www2.nationalgrid.com/WorkArea/DownloadAsset.aspx? id = 8589935616.
- The Electricity Storage Network, List of Energy Storage Plants in the UK, (2017) http://www2.nationalgrid.com/WorkArea/DownloadAsset.aspx?id=8589941197.
- [4] National Grid, Enhanced Frequency Response Market Information Report, (2016), pp. 1–3 Market Information Report v1.pdf https://www.nationalgrideso.com/sites/ eso/files/documents/EFR.
- [5] V. Knap, R. Sinha, M. Swierczynski, D. Stroe, S. Chaudhary, Grid Inertial Response with Lithium-ion Battery Energy Storage Systems, (2014) 1817–1822. doi:10.1109/ ISIE.2014.6864891.
- [6] B. Lian, A. Sims, D. Yu, C. Wang, R.W. Dunn, Optimizing LiFePO4 battery energy storage systems for frequency response in the UK system, IEEE Trans. Sustain. Energy. 8 (2017) 385–394, https://doi.org/10.1109/TSTE.2016.2600274.
- [7] S. Canevese, D. Cirio, A. Gatti, M. Rapizza, Simulation of Enhanced Frequency Response by Battery Storage Systems : the UK Versus the Continental Europe System, (2017).
- [8] D.I. Stroe, V. Knap, M. Swierczynski, A.I. Stroe, R. Teodorescu, Operation of a gridconnected lithium-ion battery energy storage system for primary frequency regulation: a battery lifetime perspective, IEEE Trans. Ind. Appl. 53 (2017) 430–438, https://doi.org/10.1109/TIA.2016.2616319.
- [9] M. Świerczynski, D.I. Stroe, A.I. Stan, R. Teodorescu, D.U. Sauer, Selection and performance-degradation modeling of limo2/li 4ti5o12 and lifepo4/c battery cells as suitable energy storage systems for grid integration with wind power plants: an example for the primary frequency regulation service, IEEE Trans. Sustain. Energy 5 (2014) 90–101, https://doi.org/10.1109/TSTE.2013.2273989.
- [10] D.I. Stroe, M. Swierczynski, A.I. Stroe, R. Laerke, P.C. Kjaer, R. Teodorescu, Degradation behavior of lithium-ion batteries based on lifetime models and field measured frequency regulation mission profile, IEEE Trans. Ind. Appl. 52 (2016) 5009–5018, https://doi.org/10.1109/TIA.2016.2597120.
- [11] J. Schmitt, A. Maheshwari, M. Heck, S. Lux, M. Vetter, Impedance change and capacity fade of lithium nickel manganese cobalt oxide-based batteries during calendar aging, J. Power Sources 353 (2017) 183–194, https://doi.org/10.1016/j. jpowsour.2017.03.090.
- [12] E. Barsoukov, J.R. Macdonald, Impedance Spectroscopy: Theory, Experiment, and Applications, (2010) http://books.google.com/books?hl = en&lr = &id = StDjdRnT72AC&oi = fnd&pg = PR9&dq = Supersymmetry: + Theory, + Experiment, + and + Cosmology&ots = VfJ4xl4eAq&sig = sh9EfE3rqkdk6iEl0Jxpbqt9oFg.
- [13] Q. Zhuang, X. Qiu, S. Xu, Diagnosis of electrochemical impedance spectroscopy in lithium-ion batteries, InTech. (2012) 189–226, https://doi.org/10.5772/26749.
- [14] J. de Hoog, J.M. Timmermans, D. Ioan-Stroe, M. Świerczynski, J. Jaguemont, S. Goutam, N. Omar, J. Van Mierlo, P. Van Den Bossche, Combined cycling and calendar capacity fade modeling of a Nickel-Manganese-Cobalt Oxide Cell with real-life profile validation, Appl. Energy 200 (2017) 47–61, https://doi.org/10. 1016/j.apenergy.2017.05.018.
- [15] S. Käbitz, J.B. Gerschler, M. Ecker, Y. Yurdagel, B. Emmermacher, D. André, T. Mitsch, D.U. Sauer, Cycle and calendar life study of a graphite|LiNi1/3Mn 1/ 3Co1/3O2 Li-ion high energy system. Part A: Full cell characterization, J. Power Sources 239 (2013) 572–583, https://doi.org/10.1016/j.jpowsour.2013.03.045.
- [16] M. Ecker, N. Nieto, S. Käbitz, J. Schmalstieg, H. Blanke, A. Warnecke, D.U. Sauer, Calendar and cycle life study of Li(NiMnCo)O2-based 18650 lithium-ion batteries, J. Power Sources 248 (2014) 839–851, https://doi.org/10.1016/j.jpowsour.2013.09.143.
- [17] M. Ceraolo, G. Lutzemberger, D. Poli, Aging evaluation of high power lithium cells subjected to micro-cycles, J. Energy Storage 6 (2016) 116–124, https://doi.org/10. 1016/j.est.2016.03.006.

- [18] I. Baghdadi, O. Briat, J.Y. Delétage, P. Gyan, J.M. Vinassa, Lithium battery aging model based on Dakin's degradation approach, J. Power Sources 325 (2016) 273–285, https://doi.org/10.1016/j.jpowsour.2016.06.036.
- [19] Giorgio Rizzoni, Aging Propagation Modeling And State Of Health Assessment In Battery Systems, (2015) (accessed July 13, 2017), http://energy.case.edu/sites/ energy.case.edu/files/images/150401_cwru_seminar_rizzoni.pdf.
- [20] D. Pritzl, J. Landesfeind, H.A. Gasteiger, S. Solchenbach, An analysis protocol for three-electrode Li-Ion battery impedance spectra : part II, Anal. Graphite Anode Cycled vs. LNMO 165 (2018), https://doi.org/10.1149/2.0461810jes.
- [21] T.M. Silva, L. Guerlou-demourgues, A. Ad, C.D.Q. Estrutural-cqe, I.S. T, Application of the Mott-Schottky model to select potentials for EIS studies on electrodes for electrochemical charge storage n-M a, Electrochim. Acta 289 (2018) 47–55, https:// doi.org/10.1016/j.electacta.2018.08.077.
- [22] C. Pastor-Fernández, K. Uddin, G.H. Chouchelamane, W.D. Widanage, J. Marco, A comparison between electrochemical impedance spectroscopy and incremental capacity-differential voltage as Li-ion diagnostic techniques to identify and quantify the effects of degradation modes within battery management systems, J. Power Sources 360 (2017) 301–318, https://doi.org/10.1016/ji.jpowsour.2017.03.042.
- [23] C. Pastor-Fernandez, W. Dhammika Widanage, J. Marco, M.A. Gama-Valdez, G.H. Chouchelamane, Identification and quantification of ageing mechanisms in Lithium-ion batteries using the EIS technique, 2016 IEEE Transp. Electrif. Conf. Expo, ITEC (2016), https://doi.org/10.1109/ITEC.2016.7520198 2016.
- [24] Y. Firouz, R. Relan, J.M. Timmermans, N. Omar, P. Van Den Bossche, J. Van Mierlo, Advanced lithium ion battery modeling and nonlinear analysis based on robust method in frequency domain : nonlinear characterization and non-parametric modeling, Energy 106 (2016) 602–617, https://doi.org/10.1016/j.energy.2016.03.028.
- [25] J. Fleming, T. Amietszajew, J. Charmet, A. John, D. Greenwood, R. Bhagat, The design and impact of in-situ and operando thermal sensing for smart energy storage, J. Energy Storage 22 (2019) 36–43, https://doi.org/10.1016/j.est.2019.01.026.
- [26] N. Harting, N. Wolff, F. Röder, U. Krewer, Electrochimica acta nonlinear frequency response analysis (NFRA) of lithium-ion batteries, Electrochim. Acta 248 (2017) 133–139, https://doi.org/10.1016/j.electacta.2017.04.037.
- [27] N. Wolff, N. Harting, M. Heinrich, R. Fridolin, U. Krewer, Nonlinear frequency response analysis on lithium-ion batteries : a model-based assessment, Electrochim. Acta 260 (2018) 614–622, https://doi.org/10.1016/j.electacta.2017.12.097.
- [28] M.D. Murbach, V.W. Hu, Nonlinear electrochemical impedance spectroscopy of lithium-ion batteries : experimental approach, analysis, and initial findings, J. Electrochem. Soc. 165 (2018) 2758–2765, https://doi.org/10.1149/2.0711811jes.
- [29] P. Büschel, U. Tröltzsch, O. Kanoun, Calculation of the distribution of relaxation times for characterization of the dynamic battery behavior, Int. Multi-Conference Syst. Signals Devices (2012) 9–11, https://doi.org/10.1109/SSD.2012.6198129 SSD 2012 - Summ. Proc.
- [30] O. Kanoun, P. Büschel, T. Günther, Distribution of Relaxation Times for Effect Identification and Modeling of Impedance Spectra, (2014), pp. 1–4, https://doi. org/10.1109/I2MTC.2014.6860872.
- [31] J. Bartoszek, S. Wang, P. Jasinski, Distribution of Relaxation Times As a Method of Separation and Identification of Complex Processes Measured by Impedance Spectroscopy, (2017), pp. 1–5.
- [32] E. Tuncer, Distribution of relaxation times : an inverse problem, IEEE Trans. Dielectr. Electr. Insul. 19 (2012) 1221–1225, https://doi.org/10.1109/TDEI.2012.6259994.
- [33] E. Spahic, G. Kuhn, R. Morgenstern, G. Beck, Fast Frequency Response in UK Grid Challenges and Solution, (2016), pp. 1–6, https://doi.org/10.1049/cp.2017.0013.
- [34] Ametek Scientific Instruments, ModuLab XM ECS | Potentiostat | Solartron Analytical, (2018) (Accessed September 17, 2018), https://www.ameteksi.com/ products/potentiostats/single-channel/modulab-xm-series/modulab-xm-ecs.
- [35] National Grid, Firm Frequency Response Agreement, (2005) BM and Non Dynamic -12.05.17_0.pdf https://www.nationalgrid.com/sites/default/files/documents/Non.
- [36] National Grid, Enhanced Frequency Response, (2016) http://www2.nationalgrid. com/WorkArea/DownloadAsset.aspx?id = 8589935616.
- [37] National Grid, Firm Frequency Response (FFR), (2017) Frequency Response 1.1.pdf https://www.nationalgrid.com/sites/default/files/documents/Firm.
- [38] National Grid, Firm Frequency Response, (2016) http://www2.nationalgrid.com/ uk/services/balancing-services/frequency-response/firm-frequency-response/.
- [39] National Grid, Firm Frequency Response Tender Rules and Standard Contract Terms, (2016), pp. 1–105 SCTs - Issue 8 Feb 1st 2017_0.pdf https://www. nationalgrid.com/sites/default/files/documents/FFR.
- [40] National Grid, Firm Frequency Response: Tender Assessment Principles, (2005), pp. 1–3. Assessment Principles.pdf https://www.nationalgrideso.com/sites/eso/files/ documents/Tender.
- [41] National Grid, Mandatory Frequency Response, (2017) (Accessed January 30, 2017), http://www2.nationalgrid.com/uk/services/balancing-services/frequencyresponse/mandatory-frequency-response/.
- [42] Tom Grimwood, National Grid to Trial Weekly Frequency Response Auctions -Utility Week, (2018) (accessed September 28, 2018), https://utilityweek.co.uk/ national-grid-to-trial-weekly-frequency-response-auctions/.
- [43] Liam Stoker, National Grid Teases Huge Reforms to UK's Grid-balancing Services Market | Energy Storage News, (2018) (Accessed September 28, 2018), https:// www.energy-storage.news/news/national-grid-teases-huge-reforms-to-uks-gridbalancing-services-market.
- [44] C.R. Birkl, M.R. Roberts, E. Mcturk, P.G. Bruce, D.A. Howey, Degradation diagnostics for lithium ion cells, J. Power Sources 341 (2016) 373–386, https://doi.org/ 10.1016/j.jpowsour.2016.12.011.